

Australian Standard[®]

**The use of mechanical
ventilation and air-conditioning
in buildings**

**Part 2: Mechanical ventilation for
acceptable indoor-air quality**

This Australian standard was prepared by Committee ME/62, Mechanical Ventilation and Air Conditioning. It was approved on behalf of the Council of Standards Australia on 3 October 1990 and published on 4 March 1991.

The following interests are represented on Committee ME/62:

Association of Consulting Engineers, Australia
Australian Assembly of Fire Authorities
Australian Institute of Health Surveyors
Australian Institute of Refrigeration Air Conditioning and Heating
Australian Uniform Building Regulations Coordinating Council
Building Owners and Managers Association of Australia
Confederation of Australian Industry
Council of Air Conditioning and Mechanical Contractors Associations of Australia
Department of Administration Services, Australian Construction Services
Fire Protection Industry Associations of Australia
Insurance Council of Australia
Metal Trades Industry Association of Australia
Public Works Department, New South Wales

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 84089.

Australian Standard[®]

**The use of mechanical
ventilation and air-conditioning
in buildings**

**Part 2: Mechanical ventilation for
acceptable indoor-air quality**

First published as AS 1668.2—1976.
Second edition 1980.
Third edition 1991.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 6625 6

PREFACE

This Standard was prepared by the Standards Australia Committee on Mechanical Ventilation and Air-conditioning to supersede AS 1668 – 1980, *SAA Mechanical Ventilation and Air-conditioning Code, Part 2: Ventilation requirements*.

The main technical changes are as follows:

- (a) Outdoor airflow rates are increased for most enclosures.
- (b) Reduction in outdoor airflow rates is permitted where the return air is treated for particulate and gaseous contaminants.
- (c) Ventilation system 'Lead-time' and 'Lag-time' concepts are introduced.
- (d) New equations are used for calculation of total airflow rates in carparks.
- (e) Supply ventilation is permitted for carparks.
- (f) Alternative carpark ventilation system controlled by atmospheric contaminant concentration monitoring is described.

Editorially, consideration has been given to the incorporation of the Standard in building regulations.

In the preparation of this Standard, consideration was given to the relevant Standards published by the American Society of Heating, Refrigerating and Air-conditioning Engineers (ASHRAE) for contribution to Appendices G and J, and the American Conference of Governmental Industrial Hygienists, and acknowledgement is made of the assistance received therefrom.

© Copyright – STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

Page

SECTION 1 SCOPE AND GENERAL

1.1	SCOPE	5
1.2	APPLICATION	5
1.3	REFERENCED DOCUMENTS	5
1.4	DEFINITIONS	7

SECTION 2 SUPPLY AIR DILUTION PROCEDURE

2.1	SCOPE OF SECTION	10
2.2	OUTDOOR AIR INTAKES	10
2.3	OUTDOOR AIRFLOW RATES	10
2.4	PROHIBITION OF RECYCLE AIR	13
2.5	OUTDOOR AIR MIXING AND DISTRIBUTION	14
2.6	OUTDOOR AIR FLOW	14

SECTION 3 EXHAUST AIR DILUTION PROCEDURE

3.1	SCOPE OF SECTION	17
3.2	GENERAL EXHAUST VENTILATION	17
3.3	LOCAL EXHAUST	17
3.4	AIR FROM ENCLOSURES HAVING EXHAUST-AIR REQUIREMENTS	18
3.5	REPLENISHMENT OF EXHAUST AIR	18
3.6	COMBINATION OF EXHAUST SYSTEMS	18
3.7	AIR DISCHARGES	18

SECTION 4 VENTILATION OF ENCLOSURES USED BY VEHICLES WITH INTERNAL COMBUSTION ENGINES

4.1	SCOPE OF SECTION	20
4.2	APPLICATION OF SECTION	20
4.3	GENERAL CASE	20
4.4	CARPARKS	20
4.5	ENCLOSURES OTHER THAN CARPARKS	28
4.6	QUEUING AREAS	29
4.7	AIR PRESSURE	30
4.8	REPLENISHMENT OF EXHAUST AIR	30
4.9	EXHAUST-AIR DISCHARGE	30
4.10	STAFF – VENTILATION RATE	30
4.11	LOCATION OF EXHAUSTS IN BELOW GROUND ENCLOSURES	30
4.12	ENERGY SAVING	30
4.13	MONITORING OF ATMOSPHERIC CONTAMINANTS	30

APPENDICES

A	MINIMUM OUTDOOR-AIR REQUIREMENTS BASED ON CLASS OF OCCUPANCY	33
B	MINIMUM EXHAUST AIR REQUIREMENTS BASED ON USE OF ENCLOSURE	37
C	OUTDOOR AIR CONTAMINANT LEVELS	38
D	DERIVATION OF THE MULTIPLE ENCLOSURE FACTOR AND EQUATIONS FOR FILTRATION EFFICIENCIES IN A SINGLE AND SOME MULTIPLE ENCLOSURE SYSTEMS	39
E	KITCHEN EXHAUST HOODS	62
F	CAPTURE OF EMISSIONS BY KITCHEN EXHAUST HOODS	64
G	A PERFORMANCE APPROACH TO ACCEPTABLE INDOOR AIR QUALITY	68

H	VENTILATION REQUIREMENTS FOR INCINERETTES	70
J	RATIONALE FOR LAG OR LEAD TIME FOR TRANSIENT OCCUPANCY	71
K	BASIS FOR LENGTH OF VEHICLE QUEUE	72
L	EXAMPLES OF LAYOUTS OF CARPARK VENTILATION	73
M	AUTOMATIC MONITORING SYSTEMS FOR CARPARKS MARKING, COMMISSIONING, RELIABILITY AND RECORDS	78

STANDARDS AUSTRALIA

Australian Standard

The use of mechanical ventilation and air-conditioning in buildings

Part 2: Mechanical ventilation for acceptable indoor-air quality

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE This Standard sets out requirements for air-handling systems which ventilate enclosures by mechanical means, where such systems are required by a Regulatory Authority. It sets minimum requirements for preventing an excess accumulation of airborne contaminants, or objectionable odours. These minima are based on needs for body odour control, food odour control, air contaminant control, or carbon dioxide concentrations or a combination of any or all of these factors, depending on the particular situation. It does not prescribe other requirements associated with comfort, such as temperature, humidity, air movement or noise.

This Standard also includes requirements for natural ventilation of carparks. Road tunnels are outside the scope of this Standard.

NOTES:

- 1 Fire-safety aspects related to air-handling systems are covered in AS 1668.1.
- 2 It is recommended that air-handling systems be designed, constructed and installed so that their use does not give rise to a nuisance arising from noise or vibration. For guidance on noise and vibration control see AS 1055 and AS 2107.

1.2 APPLICATION

1.2.1 Mechanical systems Where mechanical air-handling systems are required by a Regulatory Authority, they shall be selected in accordance with Figure 1.1 and as follows:

- (a) *For occupancies requiring supply ventilation* – the air-handling system shall supply outdoor air in accordance with Section 2.
- (b) *For enclosures requiring general exhaust ventilation* – the air-handling system shall extract air in accordance with Section 3, as appropriate.
- (c) *For processes or enclosures requiring local exhaust* – the air-handling system shall collect the effluents and extract air in accordance with Section 3, as appropriate.
- (d) *For enclosures accommodating automotive vehicles with internal combustion engines* – the air-handling systems shall ventilate the enclosure and dispose of the extracted air in accordance with Section 4.

1.2.2 Natural systems of carparks Where a natural ventilation system is used, it shall ventilate the enclosure in accordance with Clause 4.4.1(c).

1.3 REFERENCED DOCUMENTS The documents below are referred to in this Standard.

AS

1055	Acoustics—Description and measurement of environment noise
1132	Methods of test for air filters for use in air-conditioning and general ventilation
1132.5	Part 5: Determination of arrestance efficiency, average arrestance efficiency, dust-holding capacity, and dust-holding capacity per unit of effective face area for test dusts Nos 1, 2 and 3
1200	SAA Boiler Code
1324	Air filters for use in air-conditioning and general ventilation
1482	Electrical equipment for explosive atmospheres – Protection by ventilation – Type of protection v
1530	Methods for fire tests on building materials and structures
1530.1	Part 1: Combustibility test for materials
1668	SAA Mechanical Ventilation and Air-conditioning Code
1668.1	Part 1: Fire precautions in buildings with air-handling systems
1677	Refrigerating systems
1735	Lifts, escalators, and moving walks
2107	Acoustics—Recommended design sound levels and reverberation times for building interiors
2676	Installation and maintenance of batteries in buildings



SAI GLOBAL

This is a free 7 page sample. Access the full version online.

The remainder of this document
is available for purchase online at

www.saiglobal.com/shop

SAI Global also carries a wide range of publications from a wide variety of Standards Publishers:



SAI GLOBAL



Click on the logos to search the database online.