

Australian Standard™

**Water supply—Valves for the control of
heated water supply temperatures**

**Part 3: Requirements for field-testing,
maintenance or replacement of
thermostatic mixing valves, tempering
valves and end-of-line temperature
control devices**

This Australian Standard was prepared by Committee WS-026, Valves Primarily for Use in Heated Water Systems. It was approved on behalf of the Council of Standards Australia on 26 August 2003 and published on 20 February 2004.

The following are represented on Committee WS-026:

AUSTAP
Australian Chamber of Commerce and Industry
Australian Industry Group
Business New Zealand
Certification Bodies (Australia)
Department of Human Services (South Australia)
Gas Appliance Manufacturers Association
Housing Industry Association
Institute of Hospital Engineering Australia
Master Plumbers and Mechanical Contractors Association
Master Plumbers, Gasfitters and Drainlayers New Zealand
New Zealand Engineering Federation
NSW Health Department
Water Corporation Western Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 03186.

Australian Standard™

Water supply—Valves for the control of heated water supply temperatures

Part 3: Requirements for field-testing, maintenance or replacement of thermostatic mixing valves, tempering valves and end-of-line temperature control devices

First published as AS 4032.3—2004.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 5505 4

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee WS-026, Valves Primarily for Use in Heated Water Systems in response to community concerns following a number of incidents.

After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide network utility operators and service personnel with specified requirements for the field-testing and maintenance of the devices specified in AS 4032.1 and AS 4032.2, the frequency with which the maintenance is to be conducted together with the frequency of replacement of the temperature operating components.

This Standard is the result of requests from both industry and Authorities for specified requirements which should ensure that the performance of installed devices is maintained within requirements specified in AS 4032.1 and AS 4032.2, and in so doing minimise operational failures.

AS 4032 is a suite of Standards that covers valves for the control of hot water temperatures. The suite is comprised of the following:

AS

- 4032 Water supply—Valves for the control of heated water supply temperatures
- 4032.1 Part 1: Thermostatic mixing valves—Materials, design and performance requirements
- 4032.2 Part 2: Tempering valves and end-of-line temperature activated devices
- 4032.3 Part 3: Requirements for field testing, maintenance or replacement of thermostatic mixing valves, tempering valves and end of line temperature control devices. (This Standard)

This Standard necessarily deals with existing conditions, but is not intended to discourage innovation or to exclude materials, equipment and methods, which may be developed in the future. Revisions will be made from time to time in view of such developments and amendments to this edition will be made only when absolutely necessary.

CONTENTS

	<i>Page</i>
FOREWORD.....	4
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	5
1.2 APPLICATION	5
1.3 REFERENCED DOCUMENTS.....	5
1.4 DEFINITIONS.....	5
SECTION 2 FIELD TESTING AND MAINTENANCE	
2.1 RISK ASSESSMENT	6
2.2 FIELD TESTING	6
2.3 TEMPERATURE MEASURING EQUIPMENT	6
2.4 RECORD OF TEST RESULTS AND REPAIRS.....	6
2.5 MANAGEMENT SYSTEM.....	7
2.6 MAINTENANCE	7
2.7 REPLACEMENT OF THE TEMPERATURE ACTUATOR	7
APPENDICES	
A SAFETY REQUIREMENTS	8
B METHOD FOR TESTING AND MAINTAINING THERMOSTATIC MIXING VALVES	9
C METHOD FOR TESTING AND MAINTAINING TEMPERING VALVES	11
D METHOD FOR TESTING THE FUNCTION OF END-OF-LINE TEMPERATURE- ACTUATED DEVICES	12
E TYPICAL FORMAT FOR REPORTING TEST RESULTS.....	13

FOREWORD

Attention is drawn to relevant statutory requirements with respect to the following:

- (a) The qualifications of persons permitted by law to field-test and maintain fittings specified in AS 4032.1 and AS 4032.2.
- (b) The administrative procedures that are to be followed.
- (c) The authorization of materials, fittings and other components for connection to a water service.

STANDARDS AUSTRALIA

Australian Standard

Water supply—Valves for the control of heated water supply temperatures

Part 3: Requirements for field-testing, maintenance or replacement of thermostatic mixing valves, tempering valves and end-of-line temperature control devices

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies minimum requirements for field-testing and maintenance/replacement of thermostatic mixing valves, tempering valves and end-of-line temperature-actuated devices.

1.2 APPLICATION

This Standard shall be read in conjunction with the manufacturer's published instructions.

NOTE: This Standard should also be read in conjunction with the requirements of the relevant regulators.

1.3 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS/NZS

3500 Plumbing and drainage

3500.0 Part 0: Glossary of terms

AS

4032 Water supply—Valves for the control of heated water supply temperatures

4032.1 Part 1: Thermostatic mixing valves—Materials, design and performance requirements

4032.2 Part 2: Tempering valves and end-of-line temperature-activated devices

1.4 DEFINITIONS

For the purpose of this Standard the definitions given in AS/NZS 3500.0 and AS 4032.1 apply.

1.4.1 Field testing

Inspection and performance testing resulting in a report on requirements for ongoing maintenance and/or remedial work and/or replacement.

1.4.2 Maintenance

Work that is required to be carried out on a regular basis or as a result of a problem, to enable safe operation of the valve.



SAI GLOBAL

This is a free 7 page sample. Access the full version online.

The remainder of this document
is available for purchase online at

www.saiglobal.com/shop

SAI Global also carries a wide range of publications from a wide variety of Standards Publishers:



SAI GLOBAL



Click on the logos to search the database online.